

**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**

NO: CEIG/ACEI/EI(L)/FDA/ /2025-26

7864-7868

Office of the
Chief Electrical Inspector to Govt.,
No: 135, 1st and 2nd Floor,
6th Cross, Opp. BBMP School,
Gandhi Nagar, Bangalore-560009.

Date: 17/2/2026

To,
The Proprietor/Manager,
M/s. Chinmay Electricals,
No: 62, 2nd Cross, Mallasandra,
1st Main, Babanna Layout,
T. Dasarahalli Post,
Bangalore-560073.

Sir,

Sub: Renewal Permission for Testing and Calibration of Relays, Meters, CTs, PTs, Testing of Transformers, HT and LT Panels, Cables, Testing and Filtration of Transformer oil to M/s. Chinmay Electricals, No: 62, 2nd Cross, Mallasandra, 1st Main, Babanna Layout, T. Dasarahalli Post, Bangalore-560073.

Ref:- Letter No: Nil, Dt. 30.01.2026 from M/s. Chinmay Electricals, Bangalore

**** *
**** *
**** *

Permission is hereby accorded to ***M/s. Chinmay Electricals, No: 62, 2nd Cross, Mallasandra, 1st Main, Babanna Layout, T. Dasarahalli Post, Bangalore-560073,*** holding Class-I Electrical Contractor Licence bearing Licence No: **1CL138259BNG** valid upto **31.10.2026** to provide the following service as an additional customer facility and certificate issued thereby will be accepted by this department for the tests carried out.

- I. Testing and Calibration of Relays, CTs, PTs, Meters.
- II. Testing and Filtration of Transformer Oil, HT and LT Panels, Cables and Transformers.

*** *
*** *
*** *

THIS AUTHORISATION IS ISSUED SUBJECT TO THE FOLLOWING CONDITIONS:

1. This authorisation is valid for a period of **ONE YEAR** from the date of issue of this letter or validity of the Electrical Contractor Licence whichever is earlier.
2. The acceptance of certificates issued by the firm is not binding on the KPTCL/ESCOMS. They may insist on their own testing/calibration etc., as they deemed fit.
3. All the sub-standard meters/instruments used for calibration/testing shall be got calibrated **once in a year** by the reputed laboratories/institutions and copies of such certificates should be furnished to this office while applying for renewal.
4. An agreement may be executed on plain paper with the terms and conditions of services contract and shall be produced to this office whenever required and in case of disputes.

5. This authorization is liable to be cancelled without assigning any specific reasons if the services rendered are found to be not satisfactory.
6. Rs.30,000/- paid vide Challan No: CR0126004300392649 Dt. 29.01.2026, through e-payment at State Bank of India is hereby acknowledged towards issue of permission and renewal.
7. **This authorization shall be got renewed by submitting the application for renewal before one month from the date of expiry of this authorization letter.**

LIST OF EQUIPMENTS:-

Sl. No	Equipment Type	Make	Serial No
1	Insulation tester	Motwane	A02598121
2	IR Thermometer	Metrovi	230214565
3	Earth Resistance Tester	Metravi Pro	6AANFDA1A1
4	Relay Test Kit	Monarch	JSMA/22.001
5	Clamp meter	Fluke	58560467WS
6	Digital Multi meter	Fluke	58142069WS
7	Timer Kit	Scope	2100.02.AJ0287
8	Contact Resistance Meter	Scope	AJ0389
9	ACA Leakage Tester	Lutron	Q687615
10	Power Quality Analyzer	Krykard	4761/123467 (YBH)
11	Digital Earth Resistance Tester	Metravi Pro	240936438
12	Insulation Tester	Metravi Pro	35330597
13	BDV Test Kit 80KV	PPSK	005/BDV/17
14	Filtration Unit 3000 LPM (Vehicle No: KA 04 D 9703)	Uday Filters	354
15	BDV Test Kit 100KV	NMC	25096779
16	Filtration Unit 4500 LPM (Vehicle No:KA 04 AE 8800)	Uday Filters	005

Yours faithfully,

(Dr. THEETHIRA.N.APPACHU)

**CHIEF ELECTRICAL INSPECTOR TO GOVT
BANGALORE**

**Chief Electrical Inspector to Govt.
Electrical Inspectorate
Bangalore.**

Copy for information to:

1. All the Addl. Chief Electrical Inspectors.
2. All the Dy. Chief Electrical Inspectors.
3. All the Electrical Inspectors.
4. All the Deputy Electrical Inspectors.